



OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Services
Sarjapura Road Fire Station
Bengaluru-560 035.
Date: 5/3/2023

FIRE SAFETY CERTIFICATE


NO.01/DFO/HFS/ 2023

This is Certified that the **ST. PAUL'S PUBLIC School, Sy.No.52/1 Erannapalya AC Post Bangalore-560 045.** Comprised of Ground floor & Four Upper floors, of building occupied by The Principal **ST. PAUL'S PUBLIC School Bangalore-560 045.** Have complied with the fire prevention equipment of 14 No's of ABC fire extinguishers each of 6 Kg's capacity's, 2 No's of Co2 extinguishers each of 2 kg's capacity's, Down comer system of 900 Lpm capacity, Manual call point, Signages, Fire order board, P.A System, Have been adopted in the Building , Hence these fire extinguishers are fit for One year from date of issuing this certificate.


DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560 035.

To,
The Principal,
ST. PAUL'S PUBLIC School,
Sy.No.52/1 Erannapalya
AC Post Bangalore-560 045.

ST. PAUL'S PUBLIC SCHOOL


SCHOOL MANAGER

PRINCIPAL
MARIA BENJAMIN
ST PAUL'S PUBLIC SCHOOL